



KAC Alarm Company
 Limited
 15-19 Trescott Road
 Smallwood
 Redditch
 England
 B98 7AH

T: +44 (0) 1527 406655
 F: +44 (0) 1527 406677
 E: sales@kac.co.uk
 W: www.kac.co.uk



call points

door magnets

detectors

sounders
strobos

pull stations

Suppression System Call Point



WY2001/SY

Fire Protection Devices to complement the fire range, to provide extinguishant release, hold off and extract activation for gas extinguishant system applications.

Device Type	Break Glass	Momentary Action Push Button	3 Position key operated switch
<i>Installation</i>	INDOOR		
<i>Ingress Protection</i>	IP24D		
<i>Circuit Configuration</i>	Single Pole Changeover		One open contact in each operated position
<i>Max Contact Rating</i>	240Vac 3A 24Vdc 3A	240Vac 6A 24Vdc 6A	240Vac 2A 24Vdc 6A
<i>Operating Temperature Range</i>	-30°C to +70°C		
	Order Codes		
<i>Surface</i>	WY2001/SY	WY9401/SY	WY9103/SY



WY9401/SY



WY9103/SY

E. & O.E.

Document Ref. LIT:179
 June 2002



KAC Alarm Company
 Limited
 15-19 Trescott Road
 Smallwood
 Redditch
 England
 B98 7AH

T: +44 (0) 1527 406655
 F: +44 (0) 1527 406677
 E. sales@kac.co.uk
 W: www.kac.co.uk



call points

door magnets

detectors

sounders
strobos

pull stations

Access Control Call Point



WG2001/SG
WG2200/SG

Green Call Points for Access Control Systems. Four model types offer single pole and double pole changeover in two styles of operating element, break glass or resettable.

Device Type	Break Glass	Resettable	Break Glass	Resettable
<i>Installation</i>	INDOOR			
<i>Ingress Protection</i>	IP24D			
<i>Circuit Configuration</i>	Single Pole Changeover		Double Pole Changeover	
<i>Max Contact Rating</i>	240Vac 3A 24Vdc 3A		240Vac 2A 24Vdc 2A	
<i>Operating Temperature Range</i>	-30°C to +70°C			
	Order Codes			
<i>Surface Mount</i>	WG2001/SG	WG2001/SG/F	WG2200/SG	WG2200/SG/F



WG2001/SG/F
WG2200/SG/F

E. & O.E.

Document Ref. LIT:181
May 2001